

# 2020 Consumer Confidence Report Data

## SCOTT WATER UTILITY DIST, PWS ID: 40500713

### Water System Information

If you would like to know more about the information contained in this report, please contact Larry Skaletski at (920) 468-6474.

### Opportunity for input on decisions affecting your water quality

Town of Scott Town Hall, 2621 Jody Drive, New Franken, second Monday of the month at 5:30 PM

### Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

### Source(s) of Water

Source ID	Source	Depth (in feet)	Status
1	Groundwater	1235	Emergency Use Only
2	Purchased Surface Water		Active
3	Purchased Surface Water		Active

### Educational Information

The sources of drinking water, both tap water and bottled water, include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally- occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which shall provide the same protection for public health.

## Definitions

### Term Definition

AL	Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
pCi/l	picocuries per liter (a measure of radioactivity)
ppm	parts per million, or milligrams per liter (mg/l)
ppb	parts per billion, or micrograms per liter (ug/l)

## Detected Contaminants

Your water was tested for many contaminants last year. We are allowed to monitor for some contaminants less frequently than once a year. The following tables list only those contaminants which were detected in your water. If a contaminant was detected last year, it will appear in the following tables without a sample date. If the contaminant was not monitored last year, but was detected within the last 5 years, it will appear in the tables below along with the sample date.

### Disinfection Byproducts

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Violation	Typical Source of Contaminant
HAA5 (ppb)	D3	60	60	21	7 - 28	No	By-product of drinking water chlorination
TTHM (ppb)	D9	80	0	47.9	43.1 - 56.3	No	By-product of drinking water chlorination

### Inorganic Contaminants

Contaminant (units)	Action Level	MCLG	90th Percentile Level Found	# of Results	Violation	Typical Source of Contaminant
COPPER (ppm)	AL=1.3	1.3	0.7410	0 of 10 results were above the action level.	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD (ppb)	AL=15	0	1.90	0 of 10 results were above the action level.	No	Corrosion of household plumbing systems; Erosion of natural deposits

## Additional Health Information

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Scott Water Utility District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).

## Detected Contaminants from Purchased Water

Our water system purchases water from GREEN BAY WATERWORKS. In addition to the detected contaminants listed above, these are the results from GREEN BAY WATERWORKS.

### Disinfection Byproducts

Contaminant (units)	MCL	MCLG	Level Found	Range	Violation
BROMATE (ppb)	10	10	3	0-7	No

### Inorganic Contaminants

Contaminant (units)	MCL	MCLG	Level Found	Range	Violation	Typical Source of Contaminant
ARSENIC (ppb)	10	n/a	0.66	0.66	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
BARIUM (ppm)	2	2	.019	.019	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
FLUORIDE (ppm)	4	4	0.70	0.63-0.85	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NITRATE (N03-N) (ppm)	10	10	0.30	0.30	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

### Radioactive Contaminants

Contaminant (units)	MCL	MCLG	Level Found	Range	Violation	Typical Source of Contaminant
GROSS ALPHA, EXCL. R & U (pCi/l)	15	n/a	0.8	0.8	No	Erosion of natural deposits
RADIUM, (226 + 228) (pCi/l)	5	0	0.4	0.4	No	Erosion of natural deposits
COMBINED URANIUM	30	n/a	0.4	0.4	No	Erosion of natural deposits

### Unregulated Contaminants

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted. EPA required us to participate in this monitoring

Contaminant (units)	Level Found	Range	Sample Date (if prior to 2020)
SODIUM (ppm)	8.3	8.3	
SULFATE (ppm)	21.33	20.0-22.0	
HAA5 (ppb)	11.6	6.38-11.6	2018 Green Bay UCMR 4
HAA6Br (ppb)	10.9	5.8-10.9	2018 Green Bay UCMR 4
HAA9 (ppb)	21.6	11.1-21.6	2018 Green Bay UCMR 4

### Turbidity Monitoring

In accordance with s. NR 810.29, Wisconsin Administrative Code, the treated surface water is monitored for turbidity to confirm that the filtered water is less than 0.1 NTU/0.3NTU. Turbidity is a measure of the cloudiness of water. We monitor for it because it is a good indicator of the effectiveness of our filtration system. During the year, the highest single, entry point turbidity measurement was 0.03 NTU. The lowest monthly percentage of samples meeting the turbidity limits was 100 percent.