

2021 Consumer Confidence Report Data

SCOTT WATER UTILITY DIST, PWS ID: 40500713

Water System Information

If you would like to know, more about the information contained in this report or would like to obtain a summary of the source water assessment , please contact Leonard (Lee) VandenLangenberg at 920-660-5030 or operator@townofscott.com.

Opportunity for input on decisions affecting your water quality

Town of Scott town hall 2621 Jody Drive New Franken WI 54229 Every first Monday of the month at 5:30 PM.

Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Source(s) of Water

ID	Source	Depth (in feet)	Status
1	Groundwater	1235	Emergency Well
2/3	Purchased Surface Water from Green Bay Waterworks PWSID 40503562		Active

Educational Information

The sources of drinking water, both tap water and bottled water, include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally- occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.

- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which shall provide the same protection for public health.

Definitions

Term Definition

AL Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

MCL Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

pCi/l picocuries per liter (a measure of radioactivity)

ppm parts per million, or milligrams per liter (mg/l)

ppb parts per billion, or micrograms per liter (ug/l)

ppt parts per trillion, or nanograms per liter (ng/l)

ug/L micrograms per liter or parts per billion

Detected Contaminants

Your water was tested for many contaminants last year. We are allowed to monitor for some contaminants less frequently than once a year. The following tables list only those contaminants which were detected in your water. If a contaminant was detected last year, it will appear in the following tables without a sample date. If the contaminant was not monitored last year, but was detected within the last 5 years, it will appear in the tables below along with the sample date.

Disinfection Byproducts

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Violation	Typical Source of Contaminant
HAA5 (ppb)	D3	60	60	16	7-11	No	By-product of drinking water chlorination
TTHM (ppb)	D9	80	0	48.7	36-64	No	By-product of drinking water chlorination

Inorganic Contaminants

Contaminant (units)	Action Level	MCLG	90th Percentile Level Found	# of Results	Sample Date (if prior to 2021)	Violation	Typical Source of Contaminant
COPPER (ppm)	AL=1.3	1.3	0.74	0 of 10 results were above the action level.	7/23/2020	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD (ppb)	AL=15	0	1.90	0 of 10 results were above the action level.	7/23/2020	No	Corrosion of household plumbing systems; Erosion of natural deposits

Additional Health Information

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Scott Water Utility District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

Purchased Water

Our water system purchases water from GREEN BAY WATERWORKS. In addition to the detected contaminants listed above, these are the results from GREEN BAY WATERWORKS.

Detected Contaminants from Purchased Water

Disinfection Byproducts

Contaminant (units)	MCL	MCLG	Level Found	Range	Violation
BROMATE (ppb)	10	10	2	0-4	No

Inorganic Contaminants

Contaminant (units)	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2021)	Violation	Typical Source of Contaminant
ARSENIC (ppb)	10	n/a	1	1	4/6/2020	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
BARIUM (ppm)	2	2	.019	.019	4/6/2020	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits

Contaminant (units)	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2021)	Violation	Typical Source of Contaminant
FLUORIDE (ppm)	4	4	0.85	0.63–0.85		No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NITRATE (N03-N) (ppm)	10	10	0.31	0.31		No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Radioactive Contaminants

Contaminant (units)	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2021)	Violation	Typical Source of Contaminant
GROSS ALPHA, EXCL. R & U (pCi/l)	15	n/a	0.8	0.8	4/6/2020	No	Erosion of natural deposits
RADIUM, (226 + 228) (pCi/l)	5	0	0.4	0.4	4/6/2020	No	Erosion of natural deposits
COMBINED URANIUM	30	n/a	0.4	0.4	4/6/2020	No	Erosion of natural deposits

Contaminants with a Health Advisory Level or a Secondary Maximum Contaminant Level

The following tables list contaminants which were detected in your water and that have either a Health Advisory Level (HAL) or a Secondary Maximum Contaminant Level (SMCL), or both. There are no violations for detections of contaminants that exceed Health Advisory Levels, Groundwater Standards or Secondary Maximum Contaminant Levels. Secondary Maximum Contaminant Levels are levels that do not present health concerns but may pose aesthetic problems such as objectionable taste, odor, or color. Health Advisory Levels are levels at which concentrations of the contaminant present a health risk.

Contaminant (units)	SMCL (ppm)	HAL (ppm)	Level Found	Range	Typical Source of Contaminant
CHLORIDE (ppm)	250	n/a	14.00	14.00	Runoff/leaching from natural deposits, road salt, water softeners
SULFATE (ppm)	250	n/a	22.00	22.00	Runoff/leaching from natural deposits, industrial wastes

Other Compliance

Monitoring Violations

Description	Contaminant Group	Sample Location	Compliance Period Beginning	Compliance Period Ending
Chem Monitoring/Reporting	Fluoride	Distribution System	9/1/2021	9/30/2021
DBP Monitoring/Reporting	TTHM	Distribution System	5/3/2022	5/13/2022

Green Bay Water monitors your drinking water for specific contaminants on a regular basis to make sure your drinking water meets health standards. During the compliance period noted in the above table, the required monitoring for fluoride was marked incomplete by the DNR because of an error made by the shipping company. After we took the sample and mailed it, the package was lost in transit and did not make it to the State Lab of Hygiene. To ensure this will not happen again, Green Bay Water staff has made our procedure for tracking sample packages more vigilant. Be advised that we have a continuous meter monitoring fluoride residual and manually test this number in our lab on our own at least three times a day to ensure safety; however, due to the circumstance, the number was not confirmed by the necessary regulators.

In May of this year, Scott Water Utility staff inadvertently took a TTHM sample at the incorrect location in the distribution system. This sampling is conducted every quarter and moving forward staff will be conscience about sampling at the correct locations.

Unregulated Contaminants

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted. EPA required us to participate in this monitoring

Contaminant (units)	Level Found	Range	Sample Date (if prior to 2021)
SODIUM (ppm)	8.1	8.1	
SULFATE (ppm)	22.0	21.0-22.0	
HAA5 (ppb)	11.6	6.38-11.6	2018 Green Bay UCMR 4
HAA6Br (ppb)	10.9	5.8-10.9	2018 Green Bay UCMR 4
HAA9 (ppb)	21.6	11.1-21.6	2018 Green Bay UCMR 4

Turbidity Monitoring

In accordance with s. NR 810.29, Wisconsin Administrative Code, the treated surface water is monitored for turbidity to confirm that the filtered water is less than 0.1 NTU/0.3NTU. Turbidity is a measure of the cloudiness of water. We monitor for it because it is a good indicator of the effectiveness of our filtration system. During the year, the highest single, entry point turbidity measurement was 0.02 NTU. The lowest monthly percentage of samples meeting the turbidity limits was 100 percent.

Note: Cryptosporidium is tested for monthly. At no time was there any detections for cryptosporidium on the raw or tap water.

PFAS Contaminants with a Recommended Health Advisory Level

Perfluoroalkyl and polyfluoroalkyl substances (PFAS) are a large group of human-made chemicals that have been used in industry and consumer products worldwide since the 1950. The following table list PFAS contaminants which were detected in your water and that have a recommended Health Advisory Level (HAL). There are no violations for detections of contaminants that exceed recommended Health Advisory Levels. The Recommended Health Advisory Levels are levels at which concentrations of the contaminant present a health risk and are based on guidance provided by the Wisconsin Department of Health Services.

Contaminant	Date Tested	Unit	HAL	Detected Level	Range	Source
Perfluorohexanoic acid (PFHxA)	2021	ppt	150,0000	1.61	nd-1.61	Drinking water is one way that people can be exposed to PFAS. In Wisconsin, two-thirds of people use groundwater as their source. PFAS can get in groundwater from places that make or use PFAS and releases from certain types of waste in landfills.
Perfluoroheptanoic acid (PFHpA)	2021	ppt	n/a	1.17	nd-1.17	
Perfluorohexanesulfonic acid (PFHxS)	2021	ppt	40	0.94	nd-0.94	
Perfluorooctanoic acid (PFOA)	2021	ppt	20	2.57	1.78-2.57	
Perfluorooctanesulfonic acid (PFOS)	2021	ppt	20	2.37	1.57-2.37	
Perfluorobutanoic acid (PFBA)	2021	ppt	10,000	3.45	1.01-3.45	
Perfluorooctane sulfonamide (FOSA)	2021	ppt	20	2.94	1.00-2.94	

HAL: Health Advisory Level: The concentration of a contaminant which, if exceeded, poses a health risk and may require a system to post a public notice.

Note: DHS recommends a combined enforcement standard of 20 ppt for PFOSA, NEt-FOSE, NEt-FOSA, NetFOSAA, PFOS, and PFOA. The recommended limit is 20 ppt for any one of these 6 compounds or the combined total of all 6.